

Water Testing Results - CCSD 1 Transportation

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen Sink	19720000-96SF	10/21/2021	9.95
Mens Bathroom	19720000-97BF	10/21/2021	5.66
Womens Bathroom	19720000-98BF	10/21/2021	8.85

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			

ND = Non Detect - Lead level is below the set detection limits of 2 ppb