

CCSD Safety Committee Meeting Report

Date: 09-19-2023

Time: 3:30pm

Location: Gold Beach Junior/Senior High School

Attendees: Joey Denbaugh, Eric Milburn, Trent White, Connie Keele

- All safety committee members walked the main building of the high school and located various issues to be addressed. They are as listed below:
 - Loose wiring from ceiling in the ASCEND room, Cover “peep” hole cut out in ASCEND room, Toilet seat cover to go back in restrooms, Address threshold height at ASCEND room, New Tread covers for steps near upper girl bathroom, Overloaded circuit in Jonna’s room, Clear space for heater in Keele’s room, Eliminate, or remove daily, any plugin smell makers, Unblock panel at Room #9, Secure cat6 cables in #9, Cover thermostat in #9, Repair floor in hallway in front of #9, Hook up phone in #10, Repair ceiling tiles in book room, Remove and surplus any unused items in book room (smartboards, supplies, etc.), Stabilize Elvis the elk, Repair switch in room #11, Cover outlet rm#12, Remove items on top of closet in #12, Repair and replace diffusers as needed, replace missing extinguisher by Swift’s rm, cover old clock boxes, Chain ladders and shut upper doors in cafeteria, fasten art in cafeteria, Add mat to walk in freezer, Remove vending machine, Cover thermostat in weight room, Cover exposed wire for kiln in art room, Wire screens are added to sinks at art room, make sure heaters are clear of items in art room, make sure ALL extinguishers are hung, keep top of water heater clear in janitor closet, bring all paint to one location, Add railing to computer lab in library, Cover holes in server room.
- Committee members discussed taking steps to resolve the numerous issues.
- Scheduled next safety committee meeting for 10-24-23 @ Riley Creek Elementary School at 3:30pm